


CORNWALL

OH Primary 2023 Trimming

- Backbone Maintenance Trimming
- Scheduled Maintenance Trimming
- Substations
- Town Boundary

Town Mileage Summary

BB METT:	18.73
SMT:	51.85
Total:	70.58



PROPRIETARY INFORMATION: The material contained on the Overhead Distribution Circuit Map shall be considered proprietary to Eversource (ES), and Users (which shall be defined as any person or entity who has received the Map through sale, purchase, exchange gift, or otherwise) shall keep it in confidence and shall not furnish or disclose it to any third party without the prior written permission of Eversource.

Date: 6/20/2022

Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand), NGCC, (c) OpenStreetMap contributors, and the GIS User Community

CORNWALL



DISTRIBUTION TREE RELIABILITY



TOTAL MILES SCHEDULED

70.6

TOWN TOTAL

94.6




BACKBONE MILES SCHEDULED

18.7

TOWN TOTAL

20.9



BLOCKED ROADS (2018-2022)

29



CUSTOMER REFUSALS & LIGHT TRIMS
(2018-2022)

34

TREE RELIABILITY 2022

CUSTOMERS SERVED

1,216

PERCENT TREE-RELATED OUTAGES

73%

OUTAGES

134

CUSTOMERS IMPACTED

620

MINUTES CUSTOMERS IMPACTED

181,438